



Chaussée de Vilvorde, 156  
Vilvoordsesteenweg 156  
B-1120 Bruxelles/Brussel  
Tel.: 32 (0)2 264 03 60  
Fax: 32 (0)2 268 89 58  
<http://www.apragaz.com>  
[info@apragaz.com](mailto:info@apragaz.com)



<b>EC TYPE - EXAMINATION</b>		<b>Certificate N°</b>
<b>In accordance with Module B of Directive 2014/90/EU on Marine Equipment</b>		<b>00/IT/117-4-REV 0</b>
<b>Manufacturer</b>	<b>Name</b>	<b>ANAF FIRE PROTECTION S.P.A.</b>
	<b>Address</b>	<b>Via del Commercio, 4 IT - 27020 Torre d'Isola (Pavia) ITALY</b>
<p><b>Concerned Equipment :</b> Portable Fire Extinguishers (Powder Stored Pressure)</p> <p><b>Type :</b> a) PS1-X ABC according to technical design ref. 32.250A.F000.00 Rev. B b) PS1-XN ABC according to technical design ref. 32.254A.F000.00 Rev. B c) PS1-P ABC according to technical design ref. 32.259A.F000.00 Rev. B</p> <p><b>Capacities :</b> 1kg <b>PS :</b> 13,98 bar <b>Set pressure:</b> max. 11 bar (+60°C) <b>Test pressure :</b> PT = 20 bar / Bursting pressure: Pr ≥ 55 bar <b>Service temperature range :</b> min. -30°C / max. +60°C <b>Used standards :</b> EN3.8:2006/AC:2007 &amp; EN3.7:2004/A1:2007</p>		
<p>The manufacturer is allowed to affix the marine CE mark  (followed by the NOBO n° and the year of manufacturing) to the approved equipment in the conditions described in article 10 of the Directive , only if the requirements stated in module D are fully complied with.</p> <p><b>The approval is valid until 05/10/2025</b></p>		
<p>APRAGAZ, acting within the scope of its notification for the purpose of the European Council Directive 2014/90/EU, certifies that the types of these pressure vessels conform with the relevant requirements of the pertinent EN 3-7; EN 3-8 standards and the Marine Equipment Directive 2014/90/EU on bases of the documentation and samples supplied for review and approval.</p>		
Date : 07/12/2020	Name : B.NEVE, ir	Position <b>General Manager</b>
Notified body identification number :	<b>0029</b>	Signature 
Notified body:	<b>APRAGAZ VZW / ASBL</b>	
Notified body reference :	<b>4434P000</b>	